



DEPARTMENT OF ELECTRICAL INSPECTORATE

Block 29, SDA Complex,
Kasumpti, Shimla (Himachal
Pradesh) 171009
Ph. No. 0177-2621020
E.mail:ceihp@rediffmail.com


NOTICE

It is brought to the notice of general public/ business/ consumer that Rule 4 of Himachal Pradesh Electricity (Duty) Rules, 2010 has entrusted department of electrical inspectorate with implementation of following provisions:

1. Consumer or occupier generating energy for his own use or consumption above 10KW capacity shall give a thirty days' notice of his intention to commission the generating plant(s) to the Chief Electrical Inspector, failing which the consumer or occupier shall be liable to penalize as per existing rules/ Regulations.
2. Consumer or occupier shall install a suitable energy meter on generating plant above 10 KW duly tested to record the units of electricity generated and owner shall pay Electricity Duty @45 paise/ unit, submit quarterly & maintain proper record.

Furthermore, Government of Himachal Pradesh, Department of MPP & Power in its notification No.MPP-F(1)-2/2005-IX-Loose dated 12.10.2020 mandated that generating units above 50 KW capacity strictly required to be inspected by the Chief Electrical Inspector/ Electrical Inspector and below the notified capacity generating units be self-certified and report be submitted to the Electrical Inspector.


It is brought to general public notice that intimation regarding installation of captive and stand by generating units (by whatsoever means) be intimated to this office. The co-operation of the general public is requested to ensure the safety of individuals, animals and loss of revenue to the Government of Himachal Pradesh.


(Er. M. K. Chopra) 6.08.2025
Chief Electrical Inspector,
Himachal Pradesh, Shimla -09
Date: 6/8/2025

No.HIMVINI/ED-1/Vol-12/2022- 325556

Copy of above forwarded to the following:

1. The Special Secretary (Power) to the Government of Himachal Pradesh, Simla-171002 w.r.t. office letter No.MPP-F-(10)34/2019-L dated 15.07.2025 for information please.
2. All the Superintending Engineers (Operation Circle), HPSEB Ltd. for information and necessary compliance in the matter please.


(Er. M. K. Chopra)
Chief Electrical Inspector,
Himachal Pradesh, Shimla -09